

State of Ohio Standard Inspection Report

Authority: Chapters 3717 and 3715 Ohio Revised Code

Name of facility DK'S FOOD MART	Check one <input type="checkbox"/> FSO <input checked="" type="checkbox"/> RFE	License number 0	Date 05/26/2016
Address 1508 11TH STREET PORTSMOUTH, OH 45662		Category/Descriptive COMMERCIAL CLASS 1 <25,000 SQ. FT.	
License holder HASMUKHBHAI PATEL	Inspection time (min) 35	Travel time (min) 15	Other
Type of visit (check) <input type="checkbox"/> Standard <input type="checkbox"/> Follow Up <input type="checkbox"/> Foodborne <input type="checkbox"/> 30 Day <input type="checkbox"/> Complaint <input checked="" type="checkbox"/> Prelicensing <input type="checkbox"/> Consultation <input type="checkbox"/> Other specify		Follow-up date (if required) / /	Sample date/result (if required) / /

**3717-1 OAC Violation Checked
Management and Personnel**

	2.1	Employee health
	2.2	Personal cleanliness
	2.3	Hygienic practices
	2.4	Supervision

Food

	3.0	Safe, unadulterated and honestly presented
	3.1	Sources, specification and original containers
	3.2	Protection from contamination after receiving
	3.3	Destruction of organisms
	3.4	Limitation of growth of organisms
	3.5	Identity, presentation, on premises labeling
	3.6	Discarding or reconditioning unsafe, adulterated
	3.7	Special requirements for highly susceptible populations

Equipment, Utensils and Linens

	4.0	Materials for construction and repair
	4.1	Design and construction
	4.2	Numbers and capacities
	4.3	Location and installation

	4.4	Maintenance and operation
	4.5	Cleaning of equipment and utensils
	4.6	Sanitizing of equipment and utensils
	4.7	Laundering
	4.8	Protection of clean items

Water, Plumbing, and Waste

	5.0	Water
	5.1	Plumbing system
	5.2	Mobile water tanks
	<input checked="" type="checkbox"/> 5.3	Sewage, other liquid waste and rainwater
	5.4	Refuse, recyclables, and returnables

Physical Facilities

	6.0	Materials for construction and repair
	6.1	Design, construction and installation
	<input checked="" type="checkbox"/> 6.2	Numbers and capacities
	6.3	Location and placement
	6.4	Maintenance and operation

Poisonous or Toxic Materials

	7.0	Labeling and identification
	7.1	Operational supplies and applications
	7.2	Storage and display separation

Special Requirements

	8.0	Fresh juice production
	8.1	Heat treatment dispensing freezers
	8.2	Custom processing
	8.3	Bulk water machine criteria
	8.4	Acidified white rice preparation criteria
	9.0	Facility layout and equipment specifications
	20	Existing facilities and equipment

Administrative

	901:3-4 OAC
	3701-21 OAC

Inspected by LOUIS BOERGER, R.S.	R.S./SIT # 3614	Licensor PCHD
Received by H.A. Patel.	Title owner	Phone -248-882-8162

State of Ohio
Continuation Report

Authority: Chapters 3717 and 3715 Ohio Revised Code

Facility Name DK'S FOOD MART	Type of inspection Prelicensing
----------------------------------------	-------------------------------------------

Violation(s) / Comment(s)

Observed no hand towels or drying device at front hand washing sink near service sink.

3717-1-06.2 Physical facilities: numbers and capacities.

(C)Handwashing sinks - hand drying provision.

Each handwashing sink or group of adjacent handwashing sinks shall be provided with:

- (1) Individual, disposable towels;
- (2) A continuous towel system that supplies the user with a clean towel;
- (3) A heated-air hand drying device; or
- (4) A hand drying device that employs an air-knife system that delivers high velocity, pressurized air at ambient temperatures.

Correct by 30 day inspection.

Observed no hand wash signage at front hand washing sink near service sink.

3717-1-06.2 Physical facilities: numbers and capacities.

(E)Handwashing signage.

A sign or poster that notifies food employees to wash their hands shall be provided at all handwashing sinks used by food employees and shall be clearly visible to food employees.

Correct by 30 day inspection.

Observed Coke fountain system drain connected directly to sanitary sewer drain system.

3717-1-05.3 Water, plumbing, and waste: sewage, other liquid waste, and rainwater.

(C)Backflow prevention.

A direct connection may not exist between the sewage system and a drain originating from equipment in which food, portable equipment, or utensils are placed

Correct by 30 day inspection by adding air gap device in drain connection.

Inspected by LOUIS BOERGER, R.S.	R.S./SIT # 3614	Licensors PCHD
Received by <i>H.A. Patel</i>	Title <i>Owner</i>	Phone -248-882-8162

As per HEA 5351 4/10 CHC Software, Inc.

As per AGR 1268 Cont. 4/10 CHC Software, Inc.